

Engine: Aksa Alternator: Aksa





SZUTEST

This generator set is manufactured in facilities certified to ISO 9001.

(€

This generator set is available with CE certification.

1 Phase Ratings, 50 Hz, PF 0,0

	Standby Rating (ESP)		Prime Rating (PRP)		
Voltage	kVA	kW	kVA	kW	Amp
230	5,00	4,50	4,50	4,20	18,00

Standby Rating (ESP):

Applicable for supplying power to varying electrical load for the duration of power interruption of a reliable utility source. ESP is in accordance with ISO 8528. Overload is not allowed.

Prime Rating (PRP):

Applicable for supplying power to varying electrical load for unlimited hours. PRP is in accordance with ISO 8528. 10 % overload capability is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046.

available for a period of 1 flour within 12-flour period

OPTIONAL EQUIPMENTS

ENGINE OTHER ACCESSORIES

ALTERNATOR

CONTROL SYSTEM

TRANSFER **SWITCH** - On request (optional)



Engine: Aksa Alternator: Aksa

• DIESEL ENGINE SPECIFICATIONS

Manufacturer		Aksa		
EU Stage		II		
Total Displacement	L	406,000		
Rated Speed (rpm)	rpm	3000		
Governor		Mechanical		
Oil Capacity	L	1,65		
Start System		12 V d.c.		
Fuel Consumption	Load	%100		
ruei Consumption	L/h	1,33		

• ALTERNATOR SPECIFICATIONS

Make		Aksa
Frequency	Hz	50
Design		Brushless, 2 poles
Phase		1
Voltage	V	230
Insulation Class		Н

DIEMENSIONS AND WEIGHT

Open Type	Dry Weight	Lenght	Width	Height	Tank Capacity
	kg.	mm.	mm.	mm.	L
AAP-4200 DF	186.00	520.00	920.00	700.00	16.00