

AAP 8000DE

Engine : Akxa



SZUTEST

This generator set is manufactured in facilities certified to ISO 9001.

CE

This generator set is available with CE certification.

1 Phase Ratings, 50 Hz, PF 0,0

Voltage	Standby Rating (ESP)		Prime Rating (PRP)		
	kVA	kw	kVA	kw	Amp
380	8,20	6,56	7,50	6,00	11,30

Standby Rating (ESP): Applicable for supplying power to varying electrical load for the duration of power interruption of a reliable utility source. ESP is in accordance with ISO 8528. Overload is not allowed.

Prime Rating (PRP): Applicable for supplying power to varying electrical load for unlimited hours. PRP is in accordance with ISO 8528. 10 % overload capability is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046.

1 OPTIONAL EQUIPMENTS

ENGINE

OTHER ACCESSORIES

CONTROL SYSTEM

TRANSFER SWITCH

AAP 8000DE

Engine : Akxa

1 DIESEL ENGINE SPECIFICATIONS

Manufacturer		Akxa
EU Stage		II
Total Displacement	L	499,000
Rated Speed (rpm)	rpm	3000
Governor		Mechanical
Oil Capacity	L	1,65
Start System		12 V d.c.
Fuel Consumption	Load	%100
	L/h	2,4

2 ALTERNATOR SPECIFICATIONS

Frequency	Hz	50
Design		Brushless, 2 poles
Phase		1
Voltage	V	380
Insulation Class		H

3 DIEMENSIONS AND WEIGHT

Open Type	Dry Weight	Lenght	Width	Height	Tank Capacity
	kg.	mm.	mm.	mm.	L
AAP 8000DE	125,00	730,00	490,00	690,00	15,00